## General Environmental Incident Summary

Incident: 3353 Date/Time Notice: 6/16/2014 0750 DEM Incident No:

Responsible Party: Kum & Go, L.C.

Date Incident:6/15/2014Time Incident:2245Duration:County:McKenzieTwp:150Rng:99Sec:24Qtr:Lat:47.79912Long:-103.28270Method:Navigation quality GPS

Location Description: Kum & Go #804 - 124 South Main Street, Watford City, ND 58854

Submitted By: Jennifer Carpenter Affiliation: Seneca Companies

Address: 4140 E. 14th Street

City: Des Moines State: IA Zip: 50313

Received By:
Contact Person:

64000 Westown Parkway West Des Moines, IA 50266

Distance Nearest Occupied Building: Release Contained: Yes

Type of Incident: pump leak

Description of Released Contaminant: Unleaded Gasoline

Volume Spilled: 25.00 gallons Ag Related: No EPA Extremely Hazardous Substance: No Reported to NRC: No

Cause of Incident:

Customer fueling and nozzle didn't shutoff/left pump unattended.

Risk Evaluation:

None

# of Fatalities: 0 # of Injuries: 0 Affected Medium: 09 - other

Potential Environmental Impacts:

None

Action Taken or Planned:

Approximately 25 gallons overflowed. Cleaned up by store personnel using kitty litter. Did not leave site.

Wastes Disposal Location: McKenzie County landfill

Agencies Involved:

Monday, July 21, 2014 Page 1 of 2

## **Updates**

Date: 6/16/2014 Status: Assigned to WM Staff: Panchol, Reuben

*Updated Volume:* 25.00 gallons

## Notes:

Release of gasoline due to pump island failure. Contained on location. Followup necessary to determine proper waste disposal.

Monday, July 21, 2014 Page 2 of 2